



The drawing consists of two cross-sectional views of a floor slab, labeled 1 and 2.

View 1 (Top): Shows a cross-section of a floor slab. A heating cable is embedded in the slab, with a heating pipe (Труба Унипайп $\varnothing 16 \times 2,0$) and a heating cable (Швеллер 8) connected to it. The cable is labeled "Отметка чистого пола" (Floor level mark). The pipe is labeled "Отметка верха плиты" (Top of slab mark). The slab is shown with a hatched pattern. Dimensions are given: 40 mm for the cable diameter and 80 mm for the pipe diameter.

View 2 (Bottom): Shows a cross-section of a floor slab. A heating pipe (Труба Унипайп $\varnothing 20 \times 2,25$) is embedded in the slab, with a heating cable (Швеллер 8) connected to it. The cable is labeled "Отметка чистого пола" (Floor level mark). The pipe is labeled "Отметка верха плиты" (Top of slab mark). The slab is shown with a hatched pattern. Dimensions are given: 40 mm for the cable diameter and 80 mm for the pipe diameter.

Эм.	Радиатор "PURMO" панельный "Ventil Compact"	
3	CV11-500-1000	3

Примечание

1. Схемы вентканалов ВЕ-1... ВЕ-21 см. раздел АР листы 24-30.
2. Тип решеток не указанных на плане принять РВП-3 120х200 по ГОСТ 13448-82.
3. Все подводки к приборам отопления "Ригто" выполнить трубой металлопластиковой "Униплайп" диаметром 16х2,0 мм
4. Разрезы по системам ВД1, ВД2, ППЗ смотреть по листу 6

[illegible]

ИИН по д.	Подпись и дата	Взам. ин.Н	ВК	Решетникова	АР	Титов
			ЭП	Богина		
			СС	Боросина		